



STOP CORONA VIRUS-Wash Your Hand/Wear Mask/Maintain Social Distance"

 Delhi Jal Board	THE TEST REPORT IS FOR THIS PARTICULAR DELHI JAL BOARD GOVT SAMPLE ONLY WATER QUALITY CONTROL LABORATORY, WATER TREATMENT PLANT HAIDERPUR, DELHI-110085.	 स्वच्छ भारत एक कदम स्वच्छता की ओर
--	---	---

Water sample collected from DJB supply in the premises of **NAVEEN PUBLIC SCHOOL**, Village Nithari, Delhi- 86, Vide challan no. - 412 dated 11.03.2024

S.No.	PARAMETERS	UNITS	Limit as per B.I.S.10500:2012		S1
			Acceptable	Permissible	
1.	Date of collection	--	--	--	16.03.2024
2.	Date of Analysis	--	--	--	22.03.2024
3.	Colour	Hazen	5	15	Clear
4.	Odour	--	Agreeable		Agreeable
5.	Turbidity	N.T.U.	1.0	5.0	0.80
6.	p ^H value	--	6.5 to 8.5	N.R.	7.3
7.	Electrical Conductivity	µMhos/cm	---	---	307.6
8.	Total Dissolved Solid	(mg/l)	500	2000	200.65
CHEMICAL EXAMINATION					
9.	Phenolphthalein Alkalinity	(mg/l)	---	---	Nil
10.	Total Alkalinity	(mg/l)	200	600	50.1
11.	Total Hardness	(mg/l)	200	600	81.0
12.	Calcium Hardness	(mg/l)	200	600	61.0
13.	Magnesium Hardness	(mg/l)	200	600	20.2
14.	Calcium as Ca	(mg/l)	75	200	24.6
15.	Magnesium as mg	(mg/l)	30	100	4.7
16.	Ammonia (as NH ₃ -N)	(mg/l)	0.5	N.R.	ND*
17.	Nitrite-Nitrogen (N)	(mg/l)	---	---	ND*
18.	Nitrate (NO ₃)	(mg/l)	45	N.R.	0.25
19.	Sulphate (SO ₄)	(mg/l)	200	400	25.87
20.	Chloride(Cl)	(mg/l)	250	1000	14.0
21.	Iron(Fe)	(mg/l)	1.0	N.R.	0.02
22.	Flurides(F)	(mg/l)	1.0	1.5	0.16
23.	Cyanides (CN)	(mg/l)	0.05	N.R.	*N.D.
24.	Residual Chlorine	(mg/l)	0.2	1.0	Nil
BACTERIOLOGICAL EXAMINATION					
25.	Coli form per 100 ml at 37°C	MPN/100mL	0		0

*N.D. -Not Detectable

Remarks: On the basis of tested parameters, water sample (S1) confirms to drinking water specification I.S.1050:2012 and may be used for drinking purpose.




Asstt. Chemist



Chemist/Bacteriologist


A.C.W.A. (HP-I)


C.W.A. (W&S)-II


Manager
NAVEEN PUBLIC SCHOOL
Recognised & Affiliated to CBSE
Village Nithari, Delhi-110086
School ID: 1412142


Principal
NAVEEN PUBLIC SCHOOL
Recognised & Affiliated to CBSE
Village Nithari, Delhi-110086
School ID: 1412142



NORTH DELHI MUNICIPAL CORPORATION
OFFICE OF DY. HEALTH OFFICER
PUBLIC HEALTH DEPARTMENT: ROHINI ZONE
SECTOR:5 : ROHINI, DELHI:110085


No. DHO/RZ/2024/410

Date: 28/03/2024


SCHOOL HEALTH CERTIFICATE


It is certified that an inspection team headed by area Astd. Public health inspector from Public Health department Rohini Zone inspected the **NAVEEN PUBLIC SCHOOL SITUATED AT VILLAGE NITHARI, DELHI-110086** and found that the **NAVEEN PUBLIC SCHOOL** has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus.

The above certificate is valid for the period of one year from date of issue.


Dy. Health Office
Rohini Zone
Deputy Health Zone
North Delhi Municipal Corp
Rohini Zone

PRINCIPAL
NAVEEN PUBLIC SCHOOL
VILLAGE NITHARI DELHI-110086


Principal
NAVEEN PUBLIC SCHOOL
Recognised & Affiliated to CBSE
Village Nithari, Delhi-110086
School ID: 1412142


Manager
NAVEEN PUBLIC SCHOOL
Recognised & Affiliated to CBSE
Village Nithari, Delhi-110086
School ID: 1412142